



APLICAÇÃO

Luminária de sobrepor

ESTRUTURA

Luminária comercial de sobrepor, corpo em chapa de aço tratada e fosfatizada com pintura eletrostática na cor branco fosco, com refletância de 92%. – Grau de Proteção IP20.


SISTEMA ÓTICO

Refletor facetado em alumínio alto brilho

EQUIPAMENTOS ELÉTRICOS

Soquetes: Policarbonato com sistema de engate rápido para T8, com travamento anti-vibratório de segurança e contatos elétricos em bronze fosforoso

CURVA FOTOMÉTRICA





ÍNDICE DE OFUSCAMENTO UNIFICADO - UGR

Glare Evaluation According to UGR																							
p. Ceiling		70	70	50	50	30	p. Walls		50	30	50	30	30	p. Floor		20	20	20	20	20	20	20	20
Room Size		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis																
X	Y																						
2H	2H	17.3	18.6	17.6	18.8	19.0	17.1	18.3	17.3	18.6	18.8												
	3H	18.9	20.1	19.3	20.3	20.6	18.7	19.8	19.0	20.1	20.4												
	4H	19.5	20.6	19.9	20.9	21.2	19.3	20.4	19.6	20.7	20.9												
	6H	20.0	21.0	20.3	21.3	21.6	19.7	20.8	20.1	21.1	21.4												
	8H	20.1	21.1	20.5	21.4	21.7	19.9	20.9	20.3	21.2	21.5												
4H	12H	20.2	21.1	20.6	21.4	21.8	20.0	20.9	20.4	21.2	21.6												
	2H	17.8	18.9	18.1	19.2	19.4	17.6	18.7	17.9	19.0	19.2												
	3H	19.7	20.6	20.0	20.9	21.2	19.4	20.4	19.8	20.7	21.0												
	4H	20.4	21.2	20.8	21.6	21.9	20.2	21.0	20.6	21.4	21.7												
	6H	21.0	21.7	21.4	22.1	22.5	20.8	21.5	21.2	21.9	22.3												
8H	8H	21.2	21.8	21.6	22.2	22.6	21.0	21.7	21.4	22.0	22.5												
	12H	21.3	21.9	21.7	22.3	22.7	21.1	21.7	21.6	22.1	22.6												
	4H	20.7	21.3	21.1	21.7	22.1	20.5	21.2	20.9	21.6	22.0												
	6H	21.4	21.9	21.9	22.4	22.8	21.2	21.8	21.7	22.2	22.6												
	8H	21.7	22.1	22.1	22.6	23.1	21.5	22.0	22.0	22.4	22.9												
12H	12H	21.8	22.2	22.3	22.7	23.2	21.7	22.1	22.2	22.6	23.1												
	4H	20.7	21.3	21.1	21.7	22.1	20.5	21.1	21.0	21.5	22.0												
	6H	21.5	21.9	21.9	22.4	22.8	21.3	21.8	21.8	22.2	22.7												
	8H	21.8	22.2	22.3	22.6	23.1	21.6	22.0	22.1	22.5	23.0												
	Variation of the observer position for the luminaire distances S																						
S = 1.0H		+0.1 / -0.1					+0.1 / -0.1																
S = 1.5H		+0.2 / -0.4					+0.2 / -0.4																
S = 2.0H		+0.4 / -0.7					+0.4 / -0.8																
Standard table Correction Summand		BK05					BK05																
		0.0					-0.2																
Corrected Glare Indices referring to 3330lm Total Luminous Flux																							

The UGR values have been calculated according to CIE Publ. 117 Spacing-to-Height-Ratio = 1.00.

DIAGRAMA DE CONE



MODELO	INSTALAÇÃO	LÂMPADA	COMP.	LARGURA	ALTURA
ELK ECO S 2XT9W	SOBREPOR	T8	620 mm	140 mm	45 mm
ELK ECO S 2XT18W	SOBREPOR	T8	1240 mm	140 mm	45 mm
ELK ECO S 4XT9W	SOBREPOR	T8	620 mm	400 mm	45 mm